

3-phase Hybrids-FAQ

Fault code and troubleshooting steps of SHxxRT

Applicable to: SHxxRT series

High ambient temperature (Code 037)

Fault name	High ambient temperature (fault code: 037)
Fault type	Failure shutdown
Fault condition	The ambient temperature exceeds 78°C (grid-connected)/74 °C (off-grid) for 2 seconds.
Steps and method of troubleshooting	<ol style="list-style-type: none"> 1. Check whether the fan is normally working and free from dust. If the fan is abnormal, please clean or replace the fan. 2. The ambient temperature is 10°C lower than the protective value for 10s. 3. Check whether the inverter power IGBT module is normal. If it is abnormal, please replace the power board.

Line-side relay fault (Code 038)

Fault name	Line-side relay fault (fault code: 038)
Fault type	Failure shutdown
Fault condition	Contact adhesion and disconnection frequently occur on the relay; There is a fault of low phase-to-ground resistance in external grid.
Steps and method of troubleshooting	<ol style="list-style-type: none"> 1. Use a multimeter to measure the voltage to ground of inverter phases. If the voltage to ground is low, a relay fault will be reported. Check whether any external cables are broken and grounded. 2. If the voltage appears in the correct range, please replace the inverter.

Low ISO resistance (Code: 039)

Fault name	Low ISO resistance (fault code: 039)
Fault type	Failure shutdown
Fault condition	The resistance to ground is less than the set value (default value: 50k Ω).
Steps and method of troubleshooting	<ol style="list-style-type: none"> 1. External PV panel grounding check: Remove all the PV strings connected to the inverter and use a multimeter to measure the voltage to ground of the positive and negative electrodes of the strings and determine whether there is a grounding fault of the PV panel. 2. Use proper electrical measurement device for troubleshooting.

For further information, please download the user manual [here](#).

This manual is intended for professional technicians who are responsible for installation, operation, maintenance and troubleshooting of inverters, and users who need to check inverter parameters. The inverter must only be installed by professional technicians.

The professional technician is required to meet the following requirements:

- Know electronic, electrical wiring and mechanical expertise, and be familiar with electrical and mechanical schematics.
- Have received professional training related to the installation, commissioning and troubleshooting of electrical equipment.
- Be able to quickly respond to hazards or emergencies that occur during installation, commissioning and troubleshooting.
- Be familiar with local standards and relevant safety regulations of electrical systems.
- Read this manual thoroughly and understand the safety instructions related to operations.